



London  
CANADA

# Department of Planning and Development Building Division Fax

TO

FROM

PHONE NUMBER: 778-516-6000  
ATTENTION: Mike Gill

FAX NUMBER: (519) 661-5184  
PHONE NUMBER: (519) 661-2500 x 5272  
FROM: Amir Sertovic, P.Eng.

DATE: April 28<sup>th</sup>, 2016

## Century Aluminum Railing Approval Confirmation

Based on the submitted testing report dated February 01, 2016, October 15, 2016 and February 25, 2016 from Intertek, we are accepting the use of the following deck guards:

74 in. Century Aluminum 5mm Glass Railing (Intertek report # 102429832COQ-003)

48 in. Scenic Topless 10 mm Glass Railing by Century Aluminum/Deksmart Railing (Intertek report # 101821679COQ-001))

96 in. Component Picket System by Century Aluminum (Intertek report # 102024155COQ-001)

Please note that drawings that are to be submitted for building permit applications must make reference to the product and must be clearly identified. Note also that your company name must be clearly visible on your product for verification by the building inspector on site.

The approval includes the connection of the posts to the deck for concrete and pressure treated lumber.

This approval is valid as long as the 2012 edition of the Ontario Building Code is applicable and is valid for the jurisdiction of the City of London only. Application for approval will be required again if a new edition of the Ontario Building Code is issued, or revisions are made to the current edition affecting loading conditions on guards.

Note that this approval pertains to structural issues and climbability only. The guards must also satisfy 9.8.8.3 of the Ontario Building Code pertaining to height.

Please feel free to contact the undersigned if you have any questions.

Amir Sertovic, P.Eng.  
Building Engineer-Structural

**IF ANY PAGES ARE MISSING, MUTILATED, OR NOT LEGIBLE, PLEASE CALL 661-4555.**

NUMBER OF PAGES TRANSMITTED (COVER PAGE + NO. OF PAGES) 1

BY FAX ONLY  HARD COPY TO FOLLOW

This message is intended only for the use of the individual or entity to which it is addressed and may contain information that is privileged, confidential and exempt from disclosure under applicable law. If the reader of this message is not the intended recipient, or the employee or agent responsible for delivering the message to the intended recipient, you are hereby notified that any dissemination, distribution or copying of this communication is strictly prohibited. If you have received this communication in error, please notify us immediately by telephone and return the original to us by postal service at the address noted below. Thank you.